

Direct Line: 0191 419 6731
E-mail: carrie.taylor@nwl.co.uk
Your Ref: R/2021/0405/FFM

1st July 2021

Dear Sir/Madam,

Application details – LAND WITHIN SOUTH TEES DEVELOPMENT CORPORATION ADJOINING RIVER TEES AND HANSON CEMENT SOUTH BANK

Thank you for consulting Northumbrian Water on the above proposed development.

In making our response to the local planning authority Northumbrian Water will assess the impact of the proposed development on our assets and assess the capacity within Northumbrian Water's network to accommodate and treat the anticipated flows arising from the development. We do not offer comment on aspects of planning applications that are outside of our area of control.

It should also be noted that, following the transfer of private drains and sewers in 2011, there may be assets that are the responsibility of Northumbrian Water that are not yet included on our records. Care should therefore be taken prior and during any construction work with consideration to the presence of sewers on site. Should you require further information, please visit <https://www.nwl.co.uk/services/developers/>.

Having assessed the proposed development against the context outlined above I can advise that the proposed engineering operations associated with ground remediation and preparation may require a trade effluent application for the disposal of groundwater to the sewerage network. We recommend that the applicant contact Northumbrian Water to discuss this matter further. Additional information and contact details can be found at <https://www.nwl.co.uk/services/business/trade-effluent/>

For information only

We can inform you that a strategic water main crosses the red line boundary of the site and may be affected by the proposed development. Northumbrian Water do not permit a building over or close to our apparatus. We will work with the developer to establish the exact location of our assets and ensure any necessary diversion, relocation or protection measures required prior to the commencement of the development. We include this informative so that awareness is given to the presence of assets on site. For further information is available at <https://www.nwl.co.uk/services/developers/>

I trust this information is helpful to you, if you should require any further information please do not hesitate to contact me.

Yours sincerely

Carrie Taylor
Developer Services