

Direct Line: 0191 419 6731
E-mail: carrie.taylor@nwl.co.uk
Your Ref: R/2021/0465/FFM

2nd July 2021

Dear Sir/Madam,

Application details – LAND AT SOUTH BANK TEES DOCK ROAD GRANGETOWN

Thank you for consulting Northumbrian Water on the above proposed development.

In making our response to the local planning authority Northumbrian Water will assess the impact of the proposed development on our assets and assess the capacity within Northumbrian Water's network to accommodate and treat the anticipated flows arising from the development. We do not offer comment on aspects of planning applications that are outside of our area of control.

It should also be noted that, following the transfer of private drains and sewers in 2011, there may be assets that are the responsibility of Northumbrian Water that are not yet included on our records. Care should therefore be taken prior and during any construction work with consideration to the presence of sewers on site. Should you require further information, please visit <https://www.nwl.co.uk/developers.aspx>.

Having assessed the proposed development against the context outlined above we have the following comments to make:

The planning application does not provide sufficient detail with regards to the management of foul and surface water from the development for Northumbrian Water to be able to assess our capacity to treat the flows from the development. We would therefore request the following condition:

CONDITION: Prior to construction above ground floor level, a detailed scheme for the disposal of foul and surface water from the development hereby approved must be submitted to and approved in writing by the Local Planning Authority in consultation with Northumbrian Water and the Lead Local Flood Authority. Thereafter the development shall take place in accordance with the approved details.

REASON: To prevent the increased risk of flooding from any sources in accordance with the NPPF.

How to Satisfy the Condition

The developer should develop their surface water drainage solution by working through the Hierarchy of Preference contained within Revised Part H of the Building Regulations 2010. Namely:-

- Soakaway
- Watercourse, and finally
- Sewer

If sewer is the only option the developer should contact Northumbrian Water to agree allowable discharge rates and points into the public sewer network. This can be done by submitting a pre planning enquiry directly to us. Full details and guidance can be found at <https://www.nwl.co.uk/developers/predevelopment-enquiries.aspx> or telephone 0191 419 6559.

Please note that the planning permission with the above condition is not considered implementable until the condition has been discharged. Only then can an application be made for a new sewer connection under Section 106 of the Water Industry Act 1991.

I trust this information is helpful to you, if you should require any further information please do not hesitate to contact me.

Yours sincerely

Carrie Taylor
Developer Services